

Swimming Pool Inspection Report

New Haven Health Department
424 Chapel St, New Haven, CT 06511

Based on an inspection this day, the items marked below identify the violations in operation or facilities which must be corrected by the date specified below.

Name of Pool: Michael Richards Condo	Street Address: 466 Middletown Ave	Date: 2025-Jul-30 11:10
Sanitarian Code:	License Number: 22	Census Tract: 142601
		Census Tract Code: 26

1. Supervisory Personnel A person knowledgeable in the operation of the pool and in pool water chemistry must be present at all times.	In Compliance
2. Pool Water Clarity A black disc six inches in diameter on a white background placed in the deepest end of the pool bottom must be clearly visible from the pool deck.	In Compliance
3. Test Kit A test kit must be present on site for measuring PH and chlorine.	In Compliance
4. Pool Records Pool records must be kept with daily recordings of PH and chlorine levels.	In Compliance
5. Facilities Decks, dressing rooms, showers, and other rooms must be cleaned daily with a 5% chlorine solution or other fungicide.	In Compliance
6. Pool Chemical Storage Chemicals must be stored in a cool, ventilated storage area.	In Compliance
7. Accessibility to Pool Outdoor pools must be surrounded by a fence four feet high, with entry gates self-closing and self-latching. When the pool is not open for use, access to the pool must be prevented.	In Compliance
8. Lifeguards When no lifeguards are on duty, a warning sign with letters at least four inches high must state: "WARNING: NO LIFEGUARD ON DUTY."	Not In Compliance
9. Emergency Telephone There must be a telephone or other suitable device for emergency communication available in the immediate vicinity.	In Compliance
10. Signs Signs must be posted at the pool and in public dressing rooms stating the following: (A) All persons shall bathe with soap and warm water before entering the pool. (B) Any persons known or suspected of having a communicable disease shall not use the pool. (C) Spitting or blowing the nose in the pool is prohibited. (D) Running, boisterous or rough play (except supervised water sports) is prohibited. Instructions regarding emergency calls must be posted. All pools at their entrance shall have directions to the nearest phone and first aid kit. Signs must be posted stating that no diving is permitted off the deck into shallow areas of the pool.	In Compliance
11. Depth Markers Depth markers at least four inches high and in contrasting color to the pool bottom must be provided on the pool rim, at the minimum and maximum point of depth, and wherever the pool floor changes slope. Markers must be visible from both inside the pool and the pool deck.	In Compliance
12. Lifesaving Equipment Each pool must provide one unit of lifesaving equipment per 100 feet of pool perimeter. Life poles or buoys acceptable.	In Compliance
13. Overflow Gutters Water must continuously skim over the lip of the gutter when the pool is unoccupied. Gutter water should be free flowing, but the gutter should not be flooded.	In Compliance
14. Surface Skimmers The normal operating level must be maintained at the middle of the skimmer when the pool is unoccupied. When the pool is occupied, the water must not be over the skimmer.	In Compliance
15. Pool Chlorine Free: <u>2</u> Total: <u>1</u>	17. Filter Data Backwash Frequency: Type of Filter: Flow Meter Reading: Filter Washwater Disposal:
16. Pool PH Reading: <u>7.2</u>	

Inspector: Geovanny Rivera 	Person in Charge: Diane Petaway 	Date Corrections Due: 2025-Aug-06
--	---	--

Remarks: Recommended the following:

1. Clean surrounding areas to prevent grass and leaves from falling in the water.
2. Clean life-saving equipment.
3. Upgrade signage. Existing signage is broken and/or discolored.

Will return on Wednesday August 6 to reinspect and ensure these items were corrected.